



Narang Metallurgical & Spectro Services LLP

"Reliable Accuracy, Trustworthy Quality"®

"ISO - 9001 : 2015 APPROVED LABORATORY"

1E/18, Ground Floor, Jhandewalan Extn., New Delhi-110 055
Mobile: +91 98102-68092, +91 98180-33846, Phones: 011 43587980, 45652356, 43552341
E-mail: inquiry@narangtestlabs.com, nmss22@yahoo.com, Website: www.narangtestlabs.com

Party Code:

Issued to:

S14982

SG POWER PRODUCTS PVT. LTD.
PLOT No. 695-696, NH-54,
DUHAI INDL. AREA, GHAZIABAD,
UTTAR PRADESH-201206Report No: GN75996
Dt. of Issue: 13-Oct-2025
Job Order: M-28860 S
Dt. of Receipt: 03-Oct-2025

Description :

SAMPLE OF EARTH ENHANCEMENT COMPOUND WAS RECEIVED FOR TESTING.

| S.No. | COMPOSITION TEST | RESULTS |
|-------|-------------------------------|---------|
| 1. | CARBON CONTENT (GRAPHITE) | 50.90 % |
| 2. | ALUMINIUM SILICATE | 10.25 % |
| 3. | CEMENT | 20.30 % |
| 4. | SILICA (as SiO ₂) | 12.20 % |
| 5. | REMAINDER'S OTHER | BALANCE |

REMARKS: THE ABOVE TEST CONFORMS TO IEC 62561-7-2018 SPECIFICATION.

***** End Of Report *****

Verified by

Note: (i) Samples are not drawn by us.
(ii) Description of sample is as provided by the party & total liability of our work is limited to Invoice Amount.
(iii) Test Samples will be disposed after 30 days of receipt.
(iv) This report cannot be used as an evidence in a court of law without written approval of the lab.
(v) Photocopy without authentication is not valid.
(vii) Please look for our Hologram sticker for genuine report.

Facilities Available: Spectro/Wet Analysis, Mechanical Test, Impact Test, IGC, RoHS, Hardness (Rockwell, Vickers Brinell), Microstructure, Macrostructure, Salt Spray Test, Cupping, Nickel/Lead Free test in Handicrafts, Plating & Coating Thickness, Surface Roughness Tester, Paint & Water Testing, ID of PVC, Nylon, Plastics, Rubber, Bakelite, PMI & Ultrasonic testing available.

Recognised by RDSO, RITES LTD., AIR FORCE, DGQA, ONGC, DMRC Army Base Workshop Ordnance Depots & Other Govt. Agencies



Authorised Signatory